
From: Art Antczak </O=EXCHANGELABS/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=8A0FE0B8063D451EAE962B049272DBAE-ART ANTCHAK>
Sent: Monday, March 28, 2016 9:09:30 AM
To: Brett Heidtke <bheidtke@stavis.com>
Subject: Fwd: ammonia detection report

Sent from my iPhone

Begin forwarded message:

From: Mike Sirois <msirois@americanrefrigeration.net>
Date: March 28, 2016 at 7:37:16 AM EDT
To: Art Antczak <aantczak@stavis.com>
Subject: RE: ammonia detection report

The case for the handheld has the calibration certificate inside. My partner and I may be coming down to meet with Mary. If that's the case I will bring it down with me and walk the freezer with them

Michael Sirois

American Refrigeration Company

149 River Street, Suite 3

Andover, MA 01810

Phone: 978-474-4000

Fax: 978-474-4001

From: Art Antczak [<mailto:aantczak@stavis.com>]
Sent: Monday, March 28, 2016 7:34 AM
To: Mike Sirois <msirois@americanrefrigeration.net>
Subject: Re: ammonia detection report
And any calibration logs for the handhelds would be helpful.
Thanks Art

Sent from my iPhone

On Mar 28, 2016, at 7:27 AM, Art Antczak <aantczak@stavis.com> wrote:

Yes, please have someone come in this morning if possible. The department of public health will be here ta 10am.

Thanks

Art Antczak

Operations Manager

212 Northern Ave.

Suite 305, "Fish Pier West"

Boston, MA 02210

aantczak@stavis.com

617-897-1205

617-532-1805

617-592-5135

From: Mike Sirois [<mailto:msirois@americanrefrigeration.net>]

Sent: Monday, March 28, 2016 6:50 AM

To: Art Antczak <aantczak@stavis.com>

Subject: RE: ammonia detection report

Good morning Art

The detectors were last calibrated in January of 2015. That is beyond the manufacturers recommended interval of calibration annually. I can send you a statement that given the sensors were beyond the recommended calibration period, one of our technicians checked the freezer the night of the incident with our handheld detector which is calibrated every six months and did not pick up any ammonia. I can have someone come back again today with the handheld and verify the level again if they would like

Michael Sirois

American Refrigeration Company

149 River Street, Suite 3

Andover, MA 01810

Phone: 978-474-4000

Fax: 978-474-4001

From: Art Antczak [<mailto:aantczak@stavis.com>]

Sent: Monday, March 28, 2016 3:09 AM

To: Mike Sirois <msirois@americanrefrigeration.net>

Subject: RE: ammonia detection report

Good Morning Mike

The department of public health is looking to see the calibration records or maintenance records for the Ammonia sensor in the freezer. Do you have anything of that nature that I can give to them? A statement saying the sensors are in good working condition and ARC will stand by the readings may be sufficient.

Please let me know.

Art Antczak

Operations Manager

212 Northern Ave.

Suite 305, "Fish Pier West"

Boston, MA 02210

aantczak@stavis.com

617-897-1205

617-532-1805

617-592-5135

From: Mike Sirois [<mailto:msirois@americanrefrigeration.net>]

Sent: Friday, March 25, 2016 1:59 PM

To: Art Antczak <aantczak@stavis.com>

Subject: ammonia detection report

Hi Art

Here is the report on the ammonia detection. I was able to print it right from the system into a PDF. Let me know if you need anything else

Michael Sirois

American Refrigeration Company

149 River Street, Suite 3

Andover, MA 01810

Phone: 978-474-4000

Fax: 978-474-4001

STAVIS PRIVACY AND CONFIDENTIALITY WARNING! This e-mail may contain confidential and privileged material for the sole use of the intended recipient. Any review, use, distribution or disclosure by others is strictly prohibited. If you are not the intended recipient (or authorized to receive for the recipient), please contact the sender by reply e-mail and delete all copies of this message.

STAVIS PRIVACY AND CONFIDENTIALITY WARNING! This e-mail may contain confidential and privileged material for the sole use of the intended recipient. Any review, use, distribution or disclosure by others is strictly prohibited. If you are not the intended recipient (or authorized to receive for the recipient), please contact the sender by reply e-mail and delete all copies of this message.